



## BUILDING SAFETY CERTIFICATE

Annexure D

No. DB/4475

Dated: 16/08/2024

It is certified that the existing building Dasmesh Public School at Partap Singh Nagar, Kotkapura is having block(s) / Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	3	4	---	---	---	---

The building is owned/occupied by Dasmesh Public School have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of The Public Works Department (PWD) (B&R) of Punjab Executive Engineer, Faridkot on August 05, 2024 in the presence of Mr. Ajay Kumar Sharma and that the building/premises is fit for occupancy for running school with effect from August 16, 2024 for a period upto March 31, 2025 in accordance with rule and subject to compliance of the specific conditions as appended.

1. The school should have a plan to deal with an untoward incident, including the safe evacuation of children from the building during an emergency and a plan to coordinate with the appropriate department. The school should regularly review and update this plan to ensure its effectiveness.

2. If any addition, alteration, extension and modification is required or to be made by the school in this building then this office should arrange immediate inspection and after completion of that part its safety certificate should be obtained from this office again.

3. If the walls, foundations and roofs of the building collapse due to natural calamity or any other reason, then the school should immediately inform this office about the condition of the building and the building should be put into use only after conducting an inspection.

4. Fire safety and electrical safety certificate should be obtained separately from the concerned department.

5. Keeping in mind the safety of the school building, it is the responsibility of the school management to get the repair of the building in due course of time.

6. Structure Safety Certificate has been issued by Nirman Architects (MJ Architects) and according to their certificate the school building is safe for use in the session 2024-25. (It should be noted that school is not constructed by this department, therefore the structural safety cannot be ensured especially from the seismic point of view).

7. The school must provide staff members with appropriate safety training, including procedures for handling emergency first aid and evacuation protocols.

8. A sum of Rs. 20000/- (Twenty thousand only) through G.R. No. 12546303 dated 15.07.2024 has been received as building inspection fee for the covered area of the school. The fire safety certificate of the school is valid till 20.06.2025 and the school management will be responsible for renewing the fire certificate within the time limits.

9. This letter/certificate has nothing to do with ownership of school premises.

10 JAN 2025

Certified that this is true and correct  
translation in English of a documents in  
Original in Punjabi & produced before me  
Dated ..... 10/11/2025



10. This letter/certificate has no relation to the plot area of the school.

11. This sanction has nothing to do with the Scheduled Roads Act.

12. This report is not valid for legal purpose.

13. This school is situated in Partap Singh Nagar, Kotkapura and falls under the jurisdiction of Road Municipal Corporation Kotkapura.

Issued on August 16, 2024 at Faridkot by The Public Works Department (PWD) (B&R) of Punjab  
Executive Engineer, Faridkot

\*Strike out whichever is not applicable. In case of block is more than six, use separate sheet for details.

Signature with Seal: \_\_\_\_\_

Name: \_\_\_\_\_

Designation: \_\_\_\_\_

Name & Address of Department/ Office:

\_\_\_\_\_

Certified that this is true and correct  
translation in English of a documents in  
Original in Punjabi & produced before me  
Dated .....  
10/1/2025

10 JAN 2025

ATTESTED

GURMAIL SINGH SANDHU  
Notary, KOTKAPURA  
(Distt. Faridkot) PUNJAB-INDIA

10.1.2025



**ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਭਵਨ**  
**ਤੇ ਮਾਰਗ ਸਾਖਾ, ਫਰੀਦਕੋਟ Email: eepdfdpwdpb@gmail.com**

ਦੌਲ

ਮਿਸ਼ਰਪੁਲ,  
 ਦਸਮੇਸ਼ ਪਬਲਿਕ ਸਕੂਲ,  
 ਪ੍ਰਤਾਪ ਸਿੰਘ ਨਗਰ, ਕੋਟਕਪੂਰਾ  
 ਨੰ: DB/ 4475

ਮਿਤੀ: 16-08-2024

ਵਿਸ਼ਾ:

ਸਾਲ 2024-25 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ। (ਦਸਮੇਸ਼ ਪਬਲਿਕ ਸਕੂਲ, ਪ੍ਰਤਾਪ ਸਿੰਘ ਨਗਰ, ਕੋਟਕਪੂਰਾ)

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅੰਕਿਤ ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਦਾ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2024-25 ਲੈਣ ਲਈ ਆਪ ਵੱਲੋਂ ਇਸ ਦਫਤਰ ਵਿਖੇ ਪ੍ਰਾਪਤ ਹੋਇਆ ਹੈ। ਆਪ ਦੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਦੇ ਦਫਤਰ ਵੱਲੋਂ ਵਿਜ਼ੁਅਲੀ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਗਈ ਅਤੇ ਉਨ੍ਹਾਂ ਦੀ ਰਿਪੋਰਟ/ਸਿਫਾਰਿਸ਼ ਅਨੁਸਾਰ ਨਿਮਨਲਿਖਤ ਨਿਰੀਖਣਾਂ ਅਤੇ ਸ਼ਰਤਾਂ ਅਧੀਨ ਸਾਲ 2024-25 ਦਾ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਮਿਤੀ 31-03-2025 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ:-

1. ਸਕੂਲ ਕੋਲ ਕਿਸੇ ਅਣਸੁਖਾਵੀਂ ਆਪਦਾ ਨਾਲ ਨਜਿੱਠਣ ਲਈ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ ਦੌਰਾਨ ਬੱਚਿਆਂ ਨੂੰ ਬਿਲਡਿੰਗ ਵਿੱਚੋਂ ਸੁਰੱਖਿਅਤ ਬਾਹਰ ਕੱਢਣਾ ਅਤੇ ਸਬੰਧਿਤ ਵਿਭਾਗ ਨਾਲ ਤਾਲਮੇਲ ਕਰਨ ਦੀ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ। ਸਕੂਲ ਨੂੰ ਇਸ ਯੋਜਨਾ ਦੀ ਪ੍ਰਭਾਵਸ਼ੀਲਤਾ ਨੂੰ ਯਕੀਨੀ ਬਣਾਉਣ ਲਈ ਨਿਯਮਿਤ ਤੌਰ ਤੇ ਸਮੀਖਿਆ ਅਤੇ ਅਪਡੇਟ ਕਰਦੇ ਰਹਿਣਾ ਚਾਹੀਦਾ ਹੈ।
2. ਜੇਕਰ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਇਮਾਰਤ ਵਿੱਚ ਕੋਈ ਵਾਧਾ, ਤਬਦੀਲੀ, ਵਿਸਤਾਰ ਅਤੇ ਸੋਧ ਦੀ ਲੋੜ ਹੈ ਜਾਂ ਕੀਤੇ ਜਾਣੇ ਹਨ ਤਾਂ ਇਸ ਦਫਤਰ ਨੂੰ ਤਰਤੀਬ ਜਾਂਚ ਦਾ ਪ੍ਰਬੰਧ ਕੀਤੀ ਜਾਣਾ ਚਾਹੀਦਾ ਹੈ ਅਤੇ ਉਸ ਹਿੱਸੇ ਨੂੰ ਮੁਕੰਮਲ ਕਰਕੇ ਉਸਦਾ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਇਸ ਦਫਤਰ ਪਾਸੇ ਫਿਰ ਤੋਂ ਲਿਆ ਜਾਵੇ।
3. ਜੇਕਰ ਬਿਲਡਿੰਗ ਦੀਆਂ ਕੰਧਾਂ, ਨੀਂਹਾਂ ਅਤੇ ਛੱਤਾਂ ਕੁਦਰਤੀ ਆਫ਼ਤਾਂ ਜਾਂ ਕਿਸੇ ਹੋਰ ਕਾਰਨ ਕਰਕੇ ਬੈਠ ਜਾਣ ਤਾਂ ਇਸ ਸੂਰਤ ਵਿੱਚ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਦਫਤਰ ਨੂੰ ਤੁਰੰਤ ਬਿਲਡਿੰਗ ਦੀ ਹਾਲਤ ਬਾਰੇ ਸੂਚਿਤ ਕੀਤਾ ਜਾਵੇ ਅਤੇ ਨਿਰੀਖਣ ਕਰਵਾਉਣ ਉਪਰੰਤ ਹੀ ਬਿਲਡਿੰਗ ਨੂੰ ਵਰਤੋਂ ਵਿੱਚ ਲਿਆ ਜਾਵੇ।
4. ਸਬੰਧਿਤ ਵਿਭਾਗ ਤੋਂ ਵੱਖਰੇ ਤੌਰ ਤੇ ਫਾਇਰ ਸੇਫਟੀ ਅਤੇ ਇਲੈਕਟ੍ਰੀਕਲ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਪ੍ਰਾਪਤ ਕੀਤਾ ਜਾਵੇ।
5. ਸਕੂਲ ਬਿਲਡਿੰਗ ਦੀ ਸੇਫਟੀ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਬਿਲਡਿੰਗ ਦੀ ਰਿਪੇਅਰ ਕਰਵਾਉਣ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਦੀ ਹੈ। ਇਸ ਰਿਪੋਰਟ ਦੇ ਬਾਵਜੂਦ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਾਰੇ ਪੱਖਾਂ ਤੋਂ ਬਿਲਡਿੰਗ ਦੀ ਸੁਰੱਖਿਆ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੈ।
6. ਨਿਰਮਾਣ ਆਰਕੀਟੈਕਟਸ (ਐਮ.ਜੇ. ਆਰਕੀਟੈਕਟ) ਵੱਲੋਂ ਸਟਰਕਚਰਲ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਦਿੱਤਾ ਗਿਆ ਹੈ ਅਤੇ ਉਹਨਾਂ ਦੇ ਸਰਟੀਫਿਕੇਟ ਅਨੁਸਾਰ ਸਕੂਲ ਸੈਸ਼ਨ 2024-25 ਲਈ ਵਰਤੋਂ ਲਈ ਸੁਰੱਖਿਅਤ ਹੈ, ਪਰੰਤੂ ਇਸ ਸਕੂਲ ਦਾ ਨਿਰਮਾਣ ਇਸ ਵਿਭਾਗ ਵੱਲੋਂ ਨਹੀਂ ਕੀਤਾ ਗਿਆ ਹੈ, ਇਸ ਲਈ ਇਸ ਵਿਭਾਗ ਦੁਆਰਾ ਸਕੂਲ ਦੀ ਸਟਰਕਚਰਲ ਸੇਫਟੀ ਖਾਸ ਕਰਕੇ ਭੂਚਾਲ ਦੇ ਦ੍ਰਿਸ਼ਟੀਕੋਣ ਤੋਂ ਯਕੀਨੀ ਨਹੀਂ ਬਣਾਈ ਜਾ ਸਕਦੀ ਹੈ।
7. ਸਕੂਲ ਨੂੰ ਸਟਾਫ ਮੈਂਬਰਾਂ ਨੂੰ ਉਚਿਤ ਸੁਰੱਖਿਆ ਸਿਖਲਾਈ ਪ੍ਰਦਾਨ ਕਰਨੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ, ਫਸਟ ਏਡ ਅਤੇ ਨਿਕਾਸੀ ਪ੍ਰੋਟੋਕੋਲ ਨੂੰ ਸੰਭਾਲਣ ਦੀਆਂ ਪ੍ਰਕਿਰਿਆਵਾਂ ਵੀ ਸ਼ਾਮਿਲ ਹਨ।
8. ਸਕੂਲ ਦੇ ਕਵਰਡ ਏਰੀਏ ਦੇ ਹਿਸਾਬ ਨਾਲ ਜੀ.ਆਰ. ਨੰਬਰ 12546303 ਮਿਤੀ 15.07.2024 ਰਾਹੀਂ ਵੀਹ ਹਜ਼ਾਰ ਰੁਪਏ (20,000/-) ਬਿਲਡਿੰਗ ਨਿਰੀਖਣ ਫੀਸ ਵੱਜੋਂ ਪ੍ਰਾਪਤ ਕੀਤੇ। ਸਕੂਲ ਦਾ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ 20.06.2025 ਤੱਕ ਵੈਲਿਡ ਹੈ ਅਤੇ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਮੇਂ ਸੀਮਾਂ ਅੰਦਰ ਫਾਇਰ ਸਰਟੀਫਿਕੇਟ ਦੀ ਨਿਨਿਊ ਕਰਵਾਉਣ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੋਵੇਗਾ।
9. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
10. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੇ ਪਲਾਟ ਏਰੀਏ ਦਾ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
11. ਇਸ ਮਨਜ਼ੂਰੀ ਦਾ ਸ਼ਡਿਊਲਡ ਰੋਡ ਐਕਟ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
12. ਇਹ ਰਿਪੋਰਟ ਕਾਨੂੰਨੀ ਉਦੇਸ਼ ਲਈ ਵੈਲਿਡ ਨਹੀਂ ਹੈ।
13. ਇਹ ਸਕੂਲ ਪ੍ਰਤਾਪ ਸਿੰਘ ਨਗਰ, ਕੋਟਕਪੂਰਾ ਵਿੱਚ ਸਥਿਤ ਹੈ ਅਤੇ ਇਹ ਰੋਡ ਮਿਊਂਸਪਲ ਕਾਰਪੋਰੇਸ਼ਨ ਕੋਟਕਪੂਰਾ ਦੇ ਅਧਿਕਾਰ ਖੇਤਰ ਵਿੱਚ ਆਉਂਦਾ ਹੈ।

ਤਸਦੀਕਾਰੀ

ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
 ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭਤੇਮ ਸਾਖਾ,  
 ਫਰੀਦਕੋਟ।

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭਤੇਮ ਸਾਖਾ, ਕੋਟਕਪੂਰਾ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰਬਰ 133 ਮਿਤੀ 07.08.2024 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
 ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭਤੇਮ ਸਾਖਾ,  
 ਫਰੀਦਕੋਟ।

# PROFORMA FOR SAFETY OF SCHOOL BUILDING

## PART-1

(To be filled by head of School/Institute)

1. Name of the School **DASMESH PUBLIC SCHOOL**
2. Location **PARTAP SINGH NAGAR, KOTKAPURA**
3. Plot Area **1.75 ACRE**
4. Plinth Area  **$64580 \text{ sqft} + (6 \times 1) + 63568 \text{ sqft} + 63336 \text{ (sf)} + 20405 \text{ (sf)}$   
Total = 194524 sqft**
5. Number of Storey **4**
6. Year of Construction of Building **2004-05**
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given
  - a) Name of the Engineer with qualification **CONSTRUCTION UNDER OWN SUPERVISION & MR. MANJIT SINGH M.J ARCHITECTS**
  - b) Address of Engineer **NEAR PSPCL, JAITU, DISTT-FARIDKOT**
  - c) Set of Structural drawings used in the construction if available
  - d) Name & Address of the architect with qualification
8. Whether the building has been constructed for the purpose of
  - a) School **Yes/No**
  - b) Residential purpose and converted for use as a School **Yes/No**
9. Materials used for roofs
  - a) R.C.C Slabs/RBC Slabs **Yes/No**
  - b) R.S joists & Battons **Yes/No**
  - c) Wooden joists & Battons **Yes/No**
10. Materials used for walls
  - a) Mud Mortar **Yes/No**
  - b) Cement Mortar **Yes/No**
  - c) Lime mortar **Yes/No**
11. Flooring
  - a) Congremerate **Yes/No**
  - b) Terrazzo **Yes/No**
  - c) Brick Paving **Yes/No**
12. A detailed drawing indicating dimensions of the rooms, Along with size and location of doors and window (Attached) **Yes/No**
13. FOR FIRE SAFETY
  - a) Whether the width of the staircase is Mtr. **Yes/No**
  - b) Whether Portable fire extinguisher exists **Yes/No**
  - c) Whether School building is Free from inflammable & toxic material **Yes/No**
  - d) Whether cooking of food is done at a safe place **Yes/No**
  - e) Whether any Thatch or combustible material has been used **Yes/No**

**SAFETY FIRE CERTIFICATE IS ATTACHED**
14. Requirement for fire Protection Arrangements under NBC Part IV (For building height less than 15 meter)
  - a) Whether house real provided **Yes/No**
  - b) Whether down comer provided **Yes/No**
  - c) Whether underground static water storage tank of capacity 50000 Ltr. (If covered area exceeds 1500 sqm) **Yes/No**

**FIRE SAFETY CERTIFICATE OBTAINED FROM FIRE**

**Principal**  
**Dasmesh Public School**  
**KOTKAPURA.**