

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1081

Dated: 07/08/2024

It is certified that an inspection team headed by **Sub Divisional Engineer (Water Supply and Sanitation)** from **Faridkot PHED** inspected the **Dasmesh Public School , Kotkapura** on **26/07/2024** and on the basis of Water Test Report (Attached) bearing no. **DWTL/FDK/2425/00075** dated **06/08/2024** of **District Water Testing Laboratory** certified that the **Dasmesh Public School, Kotkapura** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **March 31, 2025**.



Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :

10 JAN 2025

To

Dasmesh Public School

Partap Nagar, Kotkapura

Certified that this is true and correct
translation in English of a documents in
Original in Punjabi & produced before me
Dated 15/11/2025

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

TEST REPORT

Name & Address of Customer : Dasmesh Public School PARTAB SINGH NAGAR ,KOTKAPURA		Customer Reference No.	No : Letter No.dpskkp/2024/63 Dated : 26/07/2024
		Sample Submitted by	CHARANJIT SINGH
		Date of Sample Receipt	26/07/2024
		Analysis Starting Date	27/07/2024
		Analysis completion Date	29/07/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Treated Water
Test Report No.:	DWTL/FDK/2425/00075	Date of Issue :	06/08/2024
Registration no.:	DWTL/FDK/REG2425/00218	Condition of Sample :	Sealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	DASMESH PUBLIC SCHOOL PARTAB SINGH NAGAR ,KOTKAPURA, R/O WATER / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Kot Kupura	District :	Faridkot
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.16@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	130	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	32	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	60	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	17.6	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	3.8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	40	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Faridkot

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaia Chownk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

To,

Dasmesh Public School
PARTAB SINGH NAGAR ,KOTKAPURA


No.: DWTL/FDK/2425/00075 Dated : 06/08/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Letter No.dpskkp/2024/63 Dated: 26/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 26/07/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Faridkot

ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ, ਉਪ ਮੰਡਲ ਨੰ. 1, ਫਰੀਦਕੋਟ

ਵੱਲ,

DASHMESH PUBLIC SCHOOL,
PARTAP SINGH NAGAR, KOTKAPURA.


ਨੰ: 1081

ਮਿਤੀ: 07-08-2024

ਵਿਸ਼ਾ:- ਪੀਣ ਵਾਲੇ ਪਾਣੀ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸੰਬੰਧੀ ਇਸ ਦਫਤਰ ਦੇ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਵਾਟਰ ਸੈਪਲ ਲਿਆ ਗਿਆ (ਰਿਪੋਰਟ ਨਾਲ ਨੱਥੀ ਹੈ) ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਸੈਨੀਟੇਸ਼ਨ ਵੀ ਚੈਕ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਵਧੀਆ ਪਾਇਆ ਗਿਆ। ਉਕਤ ਦੇ ਆਧਾਰ ਤੇ ਆਪ ਨੂੰ ਇਹ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਵਾਟਰ ਟੈਸਟਿੰਗ ਰਿਪੋਰਟ ਦੀ ਕਾਪੀ


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ:1,
ਫਰੀਦਕੋਟ।
04